

460

26 May 1955

MEMORANDUM

From: Board to Survey Shipyard Facilities being returned by NRDL
To: Commanding Officer, U.S. Naval Radiological Defense Laboratory and
Commander, San Francisco Naval Shipyard

Subj: Acceptance of Buildings 313 and 313A; recommendation of

Ref: (a) C.O. USNRDL and ComSanFranNavShipYd memo of 29 March 1955

Encl: (1) Dir. USNRDL ltr 3-730-97 RAS:ans of 26 May 1955

1. In accordance with reference (a), an inspection was made on 26 May of Buildings 313 and 313A to determine the acceptability for return to the Shipyard.
2. The buildings were determined to be in good order and free from all fire hazards.
3. As these buildings are to be used only for storage, the utilities were secured.
4. The condition of the buildings for security purposes was satisfactory. The keys were accepted from the representative of the NRDL and turned over to the representative of the Security Division (Code 832).
5. As the Shipyard anticipates demolishing these buildings, it is not considered that they should be rehabilitated. However, the following changes are necessary to make these buildings useable for storage:
 - a. Remove all laboratory type work benches and cabinets.
 - b. Remove temporary partitions as necessary.
 - c. Remove all extraneous electrical wiring and utility piping.
 - d. Remove fluorescent type lighting and replace with industrial storage type lighting.
6. The Director, U. S. Naval Radiological Defense Laboratory, has furnished a statement, enclosure (1), to the effect that this building is free from any harmful radiological contamination.

02043

MEMORANDUM
460

7. It is recommended that these buildings be accepted by the Shipyard.

S. WESTERVELT, LTJG, GEO, USNR
Chairman

M. J. CAPSTANICH
Fire Chief

W. J. HART, LCDR, USN
Member, USNRDL

D. H. HEREL
Security Division

LCDR W. H. HEWITT, USNR
Member, Production Department

W. E. MIXON
Recorder

Copy to:
Director, USNRDL
Code: 140
" 350
" 400
" 800
" 830 (832, 833)